

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20225294  
Address: 5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Monday, February 26, 2024

Corrective Action Required:

1	Misc	-Approval required from: Fire, Planning, Water, Field Engineer, and Special Inspection -Seal exterior wall penetration at outdoor patio and gas service -Paint exterior gas piping -Bond around the water service backflow preventer valve with 3/0 cu jumper -Install anti-backflow device at hose bibb -Secure all flexible conduits in utility room per code -Provide safety tempered glazing for east door across kitchen -Install knee protectors under accessible restroom sinks
---	------	---

Comments: