

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221049
Address: 808 NE ALGONQUIN ST, LEES SUMMIT, MO 64064806 NE ALGONQUIN ST, LEES SUMMIT, MO
64064804 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, February 26, 2024

Corrective Action Required:

1	Misc	804-OK TO ROCK
---	------	----------------

806:

-Engineer to address repair for damaged trusses above great room and above master closet **Need truss repair detail for truss above living room. A 2x4 truss member was broken and torn out from the gusset joint to the top chord and replaced with a different 2x4. Engineer to address the fix for these; fix the other broken truss with 2x4x4 ft scabs per engineer
-Sister another joist to the notched double joist under front bathroom
**Reinstall electrical
-Move GB from rear wall. Provide a receptacle per code

808-OK TO ROCK

Comments: