

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224996
Address: 520 NE TOWN CENTRE DR, Unit:Q, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, February 27, 2024

Corrective Action Required:

1	Misc	-Provide end brace/partition walls per plan with 6" studs and anchored to floor
---	------	---

Comments: