

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233585
Address: 2618 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, February 28, 2024

Informational:

1	Misc	Portal frame and covered deck okay to cover.
---	------	--

Corrective Action Required:

2	Misc	-Inspection denied no city stamped plans on site. -Provide better access to front stoop or access through garage (Walk board not allowed for access)
---	------	---

Comments: