

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214616  
Address: 1825 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Alex Fischer	Failed	Wednesday, February 28, 2024

Corrective Action Required:

1	Misc	-Missing self closing hinges at garage door -Missing exterior sump pump extension -Missing 1/2 inch through bolts at deck, joist to post, unable to see post to beam connection (covered)
---	------	---

**Comments:**