

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20236587
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed - Stop Work	Wednesday, February 28, 2024

Corrective Action Required

1	DCM5 ESC INSP DENIED	REQUESTED INSPECTION(S) DENIED DUE TO LACK OF EROSION CONTROL. EROSION CONTROL SHALL BE INSTALLED ALONG THE DISTURBED SOIL TO PROTECT THE CREEK FROM SILT RUNOFF
---	----------------------	--

Corrective Action Required

2	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. WHERE INSTALLED, BOTTOM OF THE SILT FENCE MUST BE BURIED MIN 6" BELOW SOIL. IF WATTLES ARE USED AS EROSION CONTROL, IT MUST BE STAKED DOWN TIGHT TO THE SOIL. ENDS OF WATTLES MUST BE LAPPED WITH NO GAPS.
---	---------------------------------	--

****STOP-WORK ISSUED UNTIL EROSION CONTROL IS IN COMPLIANCE**

Comments: