

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRCOM20226005  
**Address:** 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mitchell Schwarz	Failed - Stop Work	Thursday, February 29, 2024

Corrective Action Required  
1 Misc

-Needs engineer letter indicating that the footings for the bathroom area and pump house area are now connected to each other  
-Ok to pour

Corrective Action Required  
2 Misc

no letter uploaded or plans adjusted to reflect as poured.  
stop work issued 02/29/2024

**Comments:**