

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236587  
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Failed	Friday, March 01, 2024

Corrective Action Required:

2	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. STAKE DOWN THE WATTLE AT LAPPED JOINTS AND STAPLE SILT FENCE TO THE WOOD STAKES
---	---------------------------------------	--

**\*\*STOP-WORK ISSUED UNTIL EROSION CONTROL IS IN COMPLIANCE AND  
FOOTING REPORT IS SUBMITTED TO THE CITY**

**Comments:**