

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240759
Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Friday, March 01, 2024

Corrective Action Required:

1	Misc	-Furred out walls in rec room need vertical fire stopping every 10ft -Vertical chase in rec room for HVAC ducts need fire stopping at top -Bedroom #1 bathroom missing fire blocking foam at south wall top plate
---	------	---

Comments: