

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224909

Address: 520 NE TOWN CENTRE DR, Unit:F, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	Nick Scott	Passed	Monday, March 04, 2024

Informational:

1 Misc

Site visited to look at fire line that is connected to the building and the crews refused to pour a concrete kicker block and after a while they poured it and sent pictures.

Comments: