

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236029  
Address: 827 NE ALGONQUIN ST, LEES SUMMIT, MO 64064829 NE ALGONQUIN ST, LEES SUMMIT, MO 64064825 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Khanh Nguyen	Not Ready	Monday, March 04, 2024

Corrective Action Required:

1	Misc	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
---	------	---

-PROVIDE EROSION CONTROL ALONG THE STREET, INCLUDING THE EAST SIDE OF THE LOT  
-PROVIDE EROSION CONTROL AROUND THE REAR STORM INLET

**Comments:**