CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20233616Address:2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Occupancy Inspection - Codes Residential		Inspector:	Outcome:	Date:	
		Kyle Beard	Failed	Monday, March 04, 2024	
Partial Co	orrection:				
1	Misc	-Missing handrail at garages stairs -Adjust self closing hinges at garage stairs -Missing center bracket at hand rail going upstairs -Break off tamper proof screw at anti siphon device in basement			
Correctiv	ve Action Required:				
3	Miscellaneous Correction	Sod and splash pads are still not installed			
		TCO for both properties has already been issued			
			D extension request, please fill out an extension request form cy inspection is failed		

Comments: