

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240887  
Address: 1840 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Tuesday, March 05, 2024

Corrective Action Required:

1	Miscellaneous Correction	Exterior garage and back patio door portal passed and is okay to cover. Interior garage hold down straps are not installed at the time of portal inspection
---	--------------------------	--

**Comments:**