

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215559

Address: 451 SE OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Patrick Schonfeldt	Temporary C of O	Tuesday, March 05, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Provide vegetation, min 70% vegetation growth required</li><li>- Set all water valve boxes to grade</li><li>- Provide splash blocks or extensions at roof drain downspouts, min 36" discharge off foundations and walls</li><li>-clean any remaining construction trash/debris from site</li></ul>
---	------	--

OK for 30 day TCO, 4/5/24

**Comments:**