

DEVELOPMENT SERVICES

Residential Plan Review

March 07, 2024

Avital Homes, LLC 7500 W 151st Street, #23100 Overland Park, KS 66283 (816) 914-7128

Permit No: PRRES20240903

Plan Name:

Project Address: 1924 SW MERRYMAN DR, LEES SUMMIT, MO 64082

Parcel Number: 69700126100000000

Location: THE MANOR AT STONEY CREEK 4TH PLAT - LOTS 109-136---LOT 124

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE. UNFINISHED BASEMENT. ROOF TRUSSES - DEFERRED. UNCOVERED DECK.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Residential Plan Review Reviewed By: Andrea Sessler Approved

8. Identify type of roof/truss package (if used) complete with layout, component design, fastening details, blocking and sheathing requirements. (IRC Section 802.10)

DEFERRED

Plot Plan Review Reviewed By: Andrea Sessler Approved

1. All easements with dimensions must be provided on the plot plan.

REAR U/E IS 10'

2. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.

Planning Review RES Reviewed By: Not Required

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Residential, Decks		144	
Residential, garage		469	
Residential, Living Area (Not Finished Basement) Residential, Un-Finished basements		2026 898	
Roofing Material		Number of Bathrooms	2.5
Number of Bedrooms	4	Number of Stories	2
Number of Living Units	1	Total Living Area	2026