

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234540  
Address: 2070 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                  |
|---------------------------------|--------------|----------|------------------------|
| <b>Above Ceiling Inspection</b> | Khanh Nguyen | Failed   | Friday, March 08, 2024 |

Corrective Action Required:

1 Misc

\*\*Partial only  
Hard lids and soffits approved

\*\*Correction- All circuits serving patient care spaces, including the X-ray, shall be in compliance with NEC517.13(A)

\*\*OK to drop ceiling border tiles

\*\*Note: green MC cables not listed to be installed in wet location (underground raceway)

**Comments:**