



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110319, Building Permit - Commercial
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Thursday, August 18, 2011
Final Building Inspection - Commercial	John Borns	Passed	Thursday, August 18, 2011

Comments: GAS PIPING SYSTEM TO BE RE-TESTED BY G.C. & P.C. TO ENSURE NO LEAKS. THEN OK FOR USE AND OCCUPANCY OF CONVERTED ORGANIC CHEMISTRY LAB 203.