CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582

Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Sediment Control (ESC) Patrick Schonfeldt Failed Friday, March 08, 2024

Inspection

Corrective Action Required:

2 Misc

3-8-24 PS Address areas of concern for erosion control on site:

- address construction entrance, gravel is saturated with mud and is no
- longer acting as a filter and allowing for mud tracks on street repair all damaged areas of silt fence along perimeters
- dispose of all construction trash and debris that has collected along site

perimeter construction fence

- provide erosion control at SW corner of arboridge dr where new storm was installed to protect stream that enters inlet at 150 crossing from silt entering storm system and provide erosion control at soil pile above creek at slope

where excavated for new sanitary/storm

-address protection for storm inlets on site as noted in SWPPP report

Comments: