

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233664
Address: 2206 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Kyle Beard	Failed	Friday, March 08, 2024

Corrective Action Required:

1	Miscellaneous Correction	Grounding for gas line in electrical panel is loose and pulled out
---	-----------------------------	--

Comments: