

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236052

Address: 3712 SW MARYVILLE PL, LEES SUMMIT, MO 640823716 SW MARYVILLE PL, LEES SUMMIT, MO
640823718 SW MARYVILLE PL, LEES SUMMIT, MO 640823710 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Monday, March 11, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Can not see where gas lines are grounded at the HVAC unit -Gas lines are not bonded -3712 pressure gauge does not work
---	--------------------------	---

Comments: