

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234959
Address: 2207 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, March 12, 2024

Corrective Action Required:

1 Misc

- provide as graded plot plan
- all outlets in laundry to be GFCI protected
- spark rings on kitchen backsplash outlets where
- labe all non GFCI outlets in unfinished spaces
- repair drywall at garage entry into living space
- garage door to be self closing and latching
- water anti syphon device on basement spigot with set screw sheered off at
- secure conduit at water heater in basement
- secure A/c disconnect whip within 12"

Comments: