CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233908

Address: 2731 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Driveway Inspection Dustin Agcopra Partial Tuesday, March 12,

2024

Corrective Action Required:

1 Misc 3-11-24 Dustin A, Dw is formed. It is not compacted, not enough aggregate,

and is water standing

3-12-24 Issues addressed. Approved to pour

Comments: