

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234777  
Address: 2615 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, March 12, 2024

Corrective Action Required:

1	Misc	-provide as graded plot plan -smoke carbon to be in the immediate facility of front bedroom but not closer that 3' to bathroom -spark rings for outlets above fireplace & kitchen outlets -missing arc fault protection on multiple circuits please refer to 210.12 of NEC -outlet at front stoop will not trip -
---	------	--

Comments: