

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234777
Address: 2615 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, March 12, 2024

Corrective Action Required:

1	Misc	-provide as graded plot plan -smoke carbon to be in the immediate facility of front bedroom but not closer that 3' to bathroom -spark rings for outlets above fireplace & kitchen outlets -missing arc fault protection on multiple circuits please refer to 210.12 of NEC -outlet at front stoop will not trip -
---	------	--

Comments: