

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225144
Address: 3202 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, March 12, 2024

Corrective Action Required:

1	Misc	-guard rail required at front stoop -uncover covered manhole N side of lot -handrail for steps in garage -(2) 1/2" through bolts at deck post to beam connection
---	------	---

Comments: