

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234940
Address: 4720 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Wednesday, March 13, 2024

Corrective Action Required:

1	Misc	2-29-24 Dustin A, SW formed and slopes are to city specs. Approved to pour
		3-7-24 Dustin A, Sw is poured. Slopes are to spec. Cure is not applied correctly
		3-13-24 Dustin A, Cure has been reapplied. Passed

Comments: