

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215829  
Address: 2051 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Failed	Wednesday, March 13, 2024

Corrective Action Required:

1	Misc	3-13-24 Dustin A, DW is cracked on right panel and will need to be replaced. A new pre pour inspection will need to be performed before pouring new section
---	------	---

**Comments:**