

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240334
Address: 3529 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, March 14, 2024

Corrective Action Required:
2 Miscellaneous 3529 SE Corbin. All rough (3)
Correction

-Fire blocking missing above ceiling in basement rec room east wall right above where someone sprayed an orange arrow

Comments: