

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211323
Address: 3130 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, March 15, 2024

Corrective Action Required:

1	Misc	Submit TCO extension letter. TCO expires 03/15/24 -obtain lawn irrigation permit -repair hole in exterior wall from previous heat pump -handrail and garage to be code compliant see R311.7.8.5 Grip size
---	------	--

Comments: