

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233498
Address: 209 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|------------------------|
| Occupancy Inspection - Codes Commercial | Robb Popp | Failed | Friday, March 15, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | **Not ready for occupancy, list may be incomplete -Complete all corrections for LSF -Provide knee clearance at sink for ADA -Install spark rings at all tile wall receptacles -Provide hammer arrestors at dishwasher -Complete electrical throughout -GFCIs not tested due to lack of power -Provide panel schedule -GFCI protection at mop sink receptacle -Lower urinals to accessible height -Provide accessible restroom signage -Install toilet at north restroom' -Install handrail at back exit -Paint gas lines with corrosion resistant paint -Seal wall to floor line at restrooms -Provide ladder for roof access at next inspection |
|---|------|---|

Comments: