

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20236579
Address: 1121 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Mitchell Schwarz	Failed	Monday, March 18, 2024

Corrective Action Required:

1	Misc	-Multiple piers full of water -All piers measure 17" in diameter, plans call for 18" -Remove routs and debris for pier holes
---	------	--

Comments: