

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20214027
Address: 4721 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed - Stop Work	Monday, March 18, 2024

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	MAINTAIN EROSION CONTROL AND STREET THROUGHOUT CONSTRUCTION 4-11-23 site visited erosion control has failed. Storm gutter full of mud. Will need to be cleaned out. Street full of mud. Sidewalks are full of mud. Need to be cleaned ASAP. Silt fence needs to be replaced or fixed on both sides of the house. Please call me when you have a crew on there way to fix this. Nick Scott 816-977-5652 9-8-23-Nothing has been done. Damaged silt fence need to be replaced and mud cleaned off sidewalk, street, and storm inlet
---	-------------------------	---

Comments: