

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240055  
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Robb Popp	Failed	Monday, March 18, 2024

Informational:	
1 Misc	Line 1 complete Line D from 1 to 2 Line A complete Line 7 from A to B

Corrective Action Required:	
2 Misc	-Remove loose soil and trash from footing -Support reinforcement to provide min 3" clearance to earth

**Comments:**