CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223975

Address: 204 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial		Kyle Beard	Partial	Monday, March 18, 2024
Informational:				
1	Miscellaneous Correction	Underground electrical from power pole to the structures west southwest corner passed. This is a partial pass only. Okay to cover.		
Informational:				
2	Miscellaneous Correction	Underground electrical fr	om main disconnect to pan	els passed. Ok to cover
		Underground electrical from panels to trash compactor		
		This is a partial pass only		

Comments: