

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234774
Address: 3736 SW MARYVILLE PL, LEES SUMMIT, MO 640823738 SW MARYVILLE PL, LEES SUMMIT, MO
640823740 SW MARYVILLE PL, LEES SUMMIT, MO 640823734 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Tuesday, March 19, 2024

Informational:
1 Misc -Unit 3740 TCO Passed, exterior not ready needs sod, splash blocks
Informational:
3 Miscellaneous 3738 SW Maryville. Occupancy (2)
Correction
-Front porch has a drop off of over 30 inches in height and needs fall protection installed
-Exterior was not ready for inspection

Passed for TCO only

3738 and 3740 SW Maryville both have passed for TCO only

Comments: