CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232433

Address: 2122 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Kyle Beard Failed Tuesday, March 19,

Residential 2024

Corrective Action Required:

1 Miscellaneous 2122 SW Rutherford. Occupancy

Correction

Front porch is required to have a guard rail installed (over 30 inch drop off)

Seal all garage ceiling penetrations

Remove pin from basement anti siphon valve Refrigerator needs to be AFCI protected

Back deck security light does not meet the 8 foot height requirement

Exterior of home is not ready for inspection

Comments: