

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231252
Address: 2126 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Tuesday, March 19, 2024

Corrective Action Required:

1	Miscellaneous Correction	Portal inspection only - garage interior tie down straps not installed - exterior garage tie down straps not nailed off - back exterior wall is not nailed off - back interior wall straps are not installed Walk your property before scheduling an inspection Not ready for inspection
---	--------------------------	--

Comments: