

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235258  
Address: 817 NE ALGONQUIN ST, LEES SUMMIT, MO 64064819 NE ALGONQUIN ST, LEES SUMMIT, MO  
64064815 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, March 19, 2024

Corrective Action Required:

1	Misc	Complete underground gas line to unit 817 and provide pressure test. All other unit tests-OK
---	------	--

**Comments:**