

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222963
Address: 2091 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Robb Popp	Failed	Tuesday, March 19, 2024

Corrective Action Required:

1	Misc	**3/19/24 -Back dated engineered letter uploaded by VAN DEURZEN AND ASSOCIATES denied. All 3rd party letters are to be uploaded to portal within 48 hours of inspection. Letter verifies only 2 of 3 installed and required piers.
---	------	--

Comments: