

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232995
Address: 2768 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, March 19, 2024

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- Final grading and sod- Provide splash pads- Sump discharge to extend 36" away from foundation- Seal exterior penetrations and electrical meter and A/C disconnect- Provide spindles, over 4 risers at garage steps
---	------	--

Comments: