

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233908
Address: 2731 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Tuesday, March 19, 2024

Informational:
1 Misc 3-12-24 Dustin A, SW is formed and aggregate compacted. Slopes are to city spec approved to pour
3-19-24 Dustin A, SW is not poured all the way. What is poured (2 panels right of drive) slopes are in compliance but cure is not applied correctly. Will need to be corrected

Comments: