

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233908
Address: 2731 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Tuesday, March 19, 2024

Corrective Action Required:

1	Misc	3-11-24 Dustin A, Dw is formed. It is not compacted, not enough aggregate, and is water standing 3-12-24 Issues addressed. Approved to pour 3-19-24 Dustin A, DW poured to city specs. Passed
---	------	---

Comments: