

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234789
Address: 519 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Retaining Wall Inspection	Robb Popp	Failed	Tuesday, March 19, 2024

Corrective Action Required:

1	Misc	-City approved, stamped plans required on site for inspections -Not completed per plan: -Use #4 bar spaced per plan -Epoxy #4 dowels to existing per plan
---	------	--

Comments: