

# Home Energy Rating Certificate

## Final Report

Rating Date: 2024-03-15

Registry ID: 715957760

Ekotrope ID: Zdm7g6j2



### HERS® Index Score:

# 61

Your home's HERS score is a relative performance score. The lower the number, the more energy efficient the home. To learn more, visit [www.hersindex.com](http://www.hersindex.com)

### Annual Savings

# \$2,285

\*Relative to an average U.S. home

### Home:

1600 SW 27th St  
Lees Summit, MO 64082

### Builder:


D and D Building, Inc

### Your Home's Estimated Energy Use:

	Use [MBtu]	Annual Cost
Heating	43.5	\$690
Cooling	4.7	\$193
Hot Water	10.9	\$362
Lights/Appliances	32.2	\$1,048
Service Charges		\$144
Generation (e.g. Solar)	0.0	\$0
<b>Total:</b>	<b>91.3</b>	<b>\$2,438</b>

### This home meets or exceeds the criteria of the following:

ENERGY STAR v3.1  
ENERGY STAR v3



### Home Feature Summary:

Home Type:	Single family detached
Model:	DD-7143
Community:	Whispering Woods
Conditioned Floor Area:	3,311 ft <sup>2</sup>
Number of Bedrooms:	4
Primary Heating System:	Furnace • Natural Gas • 96 AFUE
Primary Cooling System:	Air Conditioner • Electric • 16.4 SEER2
Primary Water Heating:	Residential Water Heater • Electric • 0.92 UEF
House Tightness:	920.5 CFM50 (1.64 ACH50)
Ventilation:	71.3 CFM • 24.96 Watts (Default) • Supply Only
Duct Leakage to Outside:	13 CFM @ 25Pa (0.39 / 100 ft <sup>2</sup> )
Above Grade Walls:	R-14
Ceiling:	Attic, R-45
Window Type:	U-Value: 0.25, SHGC: 0.22
Foundation Walls:	R-13
Framed Floor:	R-38

### Rating Completed by:

**Energy Rater:** Bryton Stoll  
RESNET ID: 2596582

**Rating Company:** Endeavor Home Performance LLC  
10424 Mastin Street, Overland Park, Kansas 66212  
913-303-9282

**Rating Provider:** Building Efficiency Resources  
PO Box 1769 Brevard, NC 28712  
800-399-9620

*Bryton Stoll*

Bryton Stoll, Certified Energy Rater  
Digitally signed: 3/18/24 at 9:13 AM



Ekotrope RATER - Version:4.2.2.3359

The Energy Rating Disclosure for this home is available from the Approved Rating Provider.  
This report does not constitute any warranty or guarantee.

## 1600 SW 27th St, Lees Summit, MO

HERS® Index Score:

**61**

Rating Date: Mar 15, 2024

HERS Registry ID: 715957760

### Annual Estimates:

Electric (kWh): 13,002.3

Natural Gas (Therms): 401.8

CO2 (Tons): 5.6

Approx. Energy Cost: \$2,298

### Rating Company:


Endeavor Home Performance  
LLC

### Rating Provider:

Building Efficiency Resources

### Rating Provider Address:

PO Box 1769 Brevard, NC  
28712



### Home Feature Summary:

Single family detached, 4  
bedrooms, 3,311 ft<sup>2</sup>

Heating: 96 AFUE

Cooling: 16.4 SEER2

Hot Water: 0.92 UEF

Air Leakage:

920.5 CFM50 (1.64 ACH50)

Ventilation:

71.3 CFM • 24.96 W (Default) •  
Supply Only

Duct LTO:

13 CFM @ 25Pa (0.39 / 100 ft<sup>2</sup>)

Above Grade Walls: R-14

Ceiling: Attic, R-45

Window: U: 0.25 • SHGC: 0.22

Foundation Walls: R-13



Ekotrope RATER - Version:

4.2.2.3359

This report does not constitute any warranty or guarantee.

# RESNET HOME ENERGY RATING

## Standard Disclosure



For home(s) located at: 1600 SW 27th St, Lees Summit, MO

Check the applicable disclosure(s):

- ☒ 1. The Rater or the Rater's employer is receiving a fee for providing the rating on this home.
- ☒ 2. In addition to the rating, the Rater or the Rater's employer has also provided the following consulting services for this home:

- ☒ A. Mechanical system design
- ☐ B. Moisture control or indoor air quality consulting
- ☐ C. Performance testing and/or commissioning other than required for the rating itself
- ☐ D. Training for sales or construction personnel
- ☐ E. Other(specify)
- ☐ 3. The Rater or the Rater's employer is:
- ☐ A. The seller of this home or their agent
- ☐ B. The mortgagor for some portion of the financed payments on this home
- ☐ C. An employee, contractor, or consultant of the electric and/or natural gas utility serving this home
- ☐ 4. The Rater or Rater's employer is a supplier or installer of products, which may include:

Products

HVAC systems

Thermal insulation systems

Air sealing of envelope or duct systems

Energy efficient appliances

Construction (builder, developer, construction contractor, etc)

Other (specify):

Installed in this home by

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

OR is in the business of

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

☐ Rater

☐ Employer

- ☐ 5. This home has been verified under the provisions of Chapter 6, Section 603 "Technical Requirements for Sampling" of the Mortgage Industry National Home Energy Rating Standard as set forth by the Residential Energy Services Network (RESNET). Rater Certification #: 2596582

Name: Bryton Stoll

Signature:

*Bryton Stoll*

Organization: Endeavor Home Performance LLC

Digitally signed:

3/18/24 at 9:13 AM

I attest that the above information is true and correct to the best of my knowledge. As a Rater or Rating Provider I abide by the rating quality control provisions of the Mortgage Industry National Home Energy Rating Standard as set forth by the Residential Energy Services Network(RESNET). The national rating quality control provisions of the rating standard are contained in Chapter One 102.1.4.6 of the standard and are posted at

<https://standards.resnet.us>

**The Home Energy Rating Standard Disclosure for this home is available from the rating provider.**

RESNET Form 03001-2 - Amended March 20, 2017



# CERTIFIED HOME

ENERGY STAR

Independently verified to meet EPA's strict guidelines for energy efficiency.

Address:

1600 SW 27th St  
Lees Summit, MO 64082

Built by:

D and D Building, Inc

Verified by:

Endeavor Home Performance LLC

Oversight by:

RESNET

Date:

Mar 18, 2024

Program/Version number:

3.1

Optional information:

Verified using Ekotrope (Version 4.2.2.3359)


Learn more at [energystar.gov/newhomes](https://energystar.gov/newhomes)



# ENERGY STAR® CERTIFIED NEW CONSTRUCTION

**Builder/Developer:** D and D Building, Inc  
**Permit Date/Number:**  
**Home/Unit Address:** 1600 SW 27th St, Lees Summit, MO 64082

**Rating Company:** Endeavor Home Performance LLC  
**Rater ID Number:** 2596582  
**Rating Date:** 2024-03-15  
**Oversight By:** RESNET  
**Program/Version Number:** 3.1



This value is not intended to be used for code compliance.

## Standard Features of ENERGY STAR Certified New Homes and Apartments

Your ENERGY STAR certified new home or apartment has been designed, constructed, and independently verified to meet rigorous requirements for energy efficiency set by the U.S. Environmental Protection Agency (EPA), including:

### Thermal Enclosure System

A complete thermal enclosure system that includes comprehensive air sealing, quality-installed insulation, and high-performing windows to deliver improved comfort and lower utility bills.

**Air Infiltration Test:** 920.5 CFM50 (1.64 ACH50)

**Primary Insulation Levels:**

**Ceiling:** R-45      **Floor:** R-38  
**Wall:** R-14      **Slab:** R-0

**Primary Window Efficiency:**

**U-Value:** 0.25      **SHGC:** 0.22



### Water Management System

A comprehensive water management system to protect roofs, walls, and foundations.

Flashing, a drainage plane, and site grading to move water from the roof to the ground and then away from the home or building.

Water-resistant materials on below-grade walls and underneath slabs to reduce the potential for water entering the home or building.

Management of moisture levels in building materials during construction.



### Heating, Cooling, and Ventilation System

A high-efficiency heating, cooling, and ventilation system that is designed and installed for optimal performance.

**Total Duct Leakage:**      **Duct Leakage to Outdoors:**  
247 CFM @ 25Pa (Post-      13 CFM @ 25Pa (0.39 / 100 ft<sup>2</sup>)  
Construction)

**Primary Heating (System Type • Fuel Type • Efficiency):**

Furnace • Natural Gas • 96 AFUE

**Primary Cooling (System Type • Fuel Type • Efficiency):**

Air Conditioner • Electric • 16.4 SEER2

**Whole-House Ventilation Type (System Type):**

Supply Only



### Energy Efficient Lighting and Appliances

Energy efficient products to help reduce utility bills, while providing high-quality performance.

**Energy Efficient Lighting:** 100%

**ENERGY STAR Certified Appliances and Fans:**

**Refrigerators:** 0      **Dishwashers:** 0  
**Ceiling Fans:** 0      **Exhaust Fans:** 0

**Primary Water Heater (System Type • Fuel Type • Efficiency):**

Residential Water Heater • Electric • 0.92 UEF



### About this certificate

The certificate provides a summary of the major energy efficiency and other construction features that contribute to this home or apartment earning the ENERGY STAR, as determined through independent inspection and verification performed by a trained professional. The Energy Rating Index or HERS index for this home, if reported, is calculated in accordance with ANSI/RESNET/ICC Standard 301, with any exceptions

approved by EPA. Because the version of Standard 301 used to calculate this index may not align with the version referenced by code, this value is not intended to be used to demonstrate compliance with code. Note that when a home or apartment contains multiple performance levels for a particular feature (e.g., window efficiency or insulation levels), the predominant value is shown. Also, homes and apartments may be certified

to earn the ENERGY STAR using a sampling protocol, whereby one home or apartment is randomly selected from a set for representative inspections and testing. In such cases, the features found in each home or apartment within the set are intended to meet or exceed the values presented on this certificate. The actual values for your home or apartment may differ, but offer equivalent or better performance.

# Building Summary



<b>Property</b> 1600 SW 27th St Lees Summit, MO 64082 Model: DD-7143 Community: Whispering Woods	<b>Organization</b> Endeavor Home Performance LLC Bryton Stoll 913-303-9282	<b>Inspection Status</b> 2024-03-15 Rater ID (RTIN): 2596582 RESNET Registered (Confirmed)
1600 SW 27th St DDB WO Finished	<b>Builder</b> D and D Building, Inc	

## General Building Information

Number Of Bedrooms	4
Number Of Floors	2
Conditioned Floor Area [sq. ft.]	3,311
Has Electric Vehicle Ready Space	No
Unconditioned, attached garage?	Yes
Conditioned Volume [cu. ft.]	33,693
Total Units in Building	1
Residence Type	Single family detached
Number of Floors in Building	-
Floor Number	-
Model	DD-7143
Community	Whispering Woods
RESNET/IECC 2006-2018 Climate Zone	4A
IECC 2021 Climate Zone	4A

## Foundation Wall

Name	Library Type	Height Above Grade	Depth Below Grade	Perimeter	Location	Enclosing
Finished 3'	16oc x4 Fbatt R13 G1	1	2	14	Exposed Exterior	Conditioned Space
Finished 6'	16oc x4 Fbatt R13 G1	1	5	10	Exposed Exterior	Conditioned Space
Finished 9'	16oc x4 Fbatt R13 G1	1	8	124	Exposed Exterior	Conditioned Space
Unfinished 9'	Uninsulated	1	8	42	Exposed Exterior	Conditioned Space

## Foundation Wall Library List

Name	Feet From Wall Top To Continuous Insulation Top	Feet From Wall Top To Continuous Insulation Bottom	Is Fully Insulated	Continuous R-value	Cavity R-value	Effective Insulation R-value
16oc x4 Fbatt R13 G1	N/A	N/A	Yes	0.00	13.00	N/A
Uninsulated	N/A	N/A	Yes	0.00	N/A	N/A

## Slab

Name	Library Type	Perimeter	Floor Grade	Carpet R	Exposed Masonry Area	Surface Area	Location	Enclosing
Basement Slab	Uninsulated	189	Below Grade	1.23	488	1,625.0 ft²	Exposed Exterior	Conditioned Space

# Building Summary



<b>Property</b> 1600 SW 27th St Lees Summit, MO 64082 Model: DD-7143 Community: Whispering Woods  1600 SW 27th St DDB WO Finished	<b>Organization</b> Endeavor Home Performance LLC Bryton Stoll 913-303-9282  <b>Builder</b> D and D Building, Inc	<b>Inspection Status</b> 2024-03-15 Rater ID (RTIN): 2596582 RESNET Registered (Confirmed)
--	---	---

## Slab Library List

Name	Wall Construction Type	Slab Completely Insulated?	Underslab Insulation Width [ft]	Perimeter Insulation Depth [ft]	Perimeter Insulation R Value	Perimeter Insulation Is Exterior	Thermal Break	Effective R-value
Uninsulated	Wood Frame / Other	No	0	0	0	Yes	No	0.00

## Framed Floor

Name	Library Type	Carpet R	Floor Grade	Surface Area	Location
Ext Cant	EXT 16oc x10 Fbib G1	1.23	Above Grade	60.0 ft²	Exposed Exterior

## Framed Floor Library List

Name	Effective R-value
EXT 16oc x10 Fbib G1	32.355

## Rim Joist

Name	Library Type	Surface Area	Location
Ext Rim	R13	132.0 ft²	Exposed Exterior
Grg Rim	R13	25.0 ft²	Unconditioned, attached garage

## Rim Joist Library List

Name	Effective Insulation R-value
R13	13.00



# Building Summary

<b>Property</b> 1600 SW 27th St Lees Summit, MO 64082 Model: DD-7143 Community: Whispering Woods	<b>Organization</b> Endeavor Home Performance LLC Bryton Stoll 913-303-9282	<b>Inspection Status</b> 2024-03-15 Rater ID (RTIN): 2596582 RESNET Registered (Confirmed)	
1600 SW 27th St DDB WO Finished	<b>Builder</b> D and D Building, Inc		

## Wall

Name	Library Type	Surface Color	Surface Area	Location
Attic x4	ATT 16oc x4 Fbib R15 G1	Medium	215.0 ft²	Attic
Ext x4	EXT 16oc x4 Fbib G1	Medium	1,386.0 ft²	Exposed Exterior
Ext x6	EXT 16oc x6 Fbib R23 (R4.1/in) G1	Medium	367.0 ft²	Exposed Exterior
Grg x4	GRG 16oc x4 Fbib G1	Medium	227.0 ft²	Unconditioned, attached garage

## Wall Library List

Name	Effective R-value
ATT 16oc x4 Fbib R15 G1	11.998
EXT 16oc x4 Fbib G1	12.121
EXT 16oc x6 Fbib R23 (R4.1/in) G1	17.559
GRG 16oc x4 Fbib G1	12.129

## Glazing

Name	Library Type	Wall Assignment	Foundation Wall Assignment	Is Operable	Overhang Depth	Overhang Ft To Top	Overhang Ft To Bottom	Orientation	Surface Area
B1.1	30/22	Ext x4		Yes	1	2	7	North	30.0 ft²
B1.2	25/22	Ext x6		Yes	2	1	3	North	10.0 ft²
B1.3.3	25/22	Ext x4		Yes	1	1	7.5	North	48.8 ft²
B1.4.2	25/22	Ext x6		Yes	2	3	9.5	North	32.5 ft²
B1.5	32/23	Ext x6		Yes	2	3	9.5	North	32.5 ft²
B1.6.2	25/22	Ext x6		Yes	2	1	3	North	10.0 ft²
B1.7.2	30/22	Ext x4		Yes	1	2	7	North	20.0 ft²
F1.1.2	30/20	Ext x6		Yes	4	3	9	South	12.0 ft²
F1.2.FV	25/25	Ext x6		Yes	4	3	11	South	24.0 ft²



# Building Summary

**Property**  
1600 SW 27th St  
Lees Summit, MO 64082  
Model: DD-7143  
Community: Whispering Woods

**Organization**  
Endeavor Home Performance LLC  
Bryton Stoll  
913-303-9282

**Inspection Status**  
2024-03-15  
Rater ID (RTIN): 2596582  
RESNET Registered (Confirmed)



1600 SW 27th St DDB  
WO Finished

**Builder**  
D and D Building, Inc

Name	Library Type	Wall Assignment	Foundation Wall Assignment	Is Operable	Overhang Depth	Overhang Ft To Top	Overhang Ft To Bottom	Orientation	Surface Area
F1.3	30/20	Ext x4		Yes	2	1	6	South	30.0 ft²
L0.1	30/22	Ext x6		Yes	0	0	0	West	15.0 ft²
L0.2	30/22	Ext x6		Yes	2	0	5	West	15.0 ft²
L1.1	25/22	Ext x4		Yes	0	0	0	West	16.0 ft²
L1.2 FV	25/22	Ext x4		Yes	2	3	10	West	21.0 ft²
L1.3	25/22	Ext x4		Yes	0	0	0	West	6.0 ft²
R1.1	30/22	Ext x4		Yes	1	1	7.5	East	16.3 ft²

## Glazing Library List

Name	Shgc	U-factor
25/22	0.22	0.250
25/25	0.25	0.250
30/20	0.2	0.300
30/22	0.22	0.300
32/23	0.23	0.320

## Skylight

None Present

## Skylight Library List

None Present

# Building Summary



<b>Property</b> 1600 SW 27th St Lees Summit, MO 64082 Model: DD-7143 Community: Whispering Woods  1600 SW 27th St DDB WO Finished	<b>Organization</b> Endeavor Home Performance LLC Bryton Stoll 913-303-9282  <b>Builder</b> D and D Building, Inc	<b>Inspection Status</b> 2024-03-15 Rater ID (RTIN): 2596582 RESNET Registered (Confirmed)
--	---	---

## Opaque Door

Name	Library Type	Wall Assignment	Foundation Wall Assignment	Emittance	Solar Absorptance	Surface Color	Surface Area	Location
Grg Door	1-3/4 Wd solid core	Grg x4		0.9	0.75	Medium	21.0 ft²	Unconditioned, attached garage

## Opaque Door Library List

Name	Effective R-value
1-3/4 Wd solid core	3.03

## Roof Insulation

Name	Library Type	Attic Exterior Area [ft²]	Clay or Concrete Roof Tiles	Surface Color	Surface Area	Location
Attic Blown	ATT 16oc x6 Fblown 16" G1	2,120	No	Medium	1,696.0 ft²	Attic
Ext Vaulted	EXT 16oc x10 Fbib R38 (R4.1/in) G1	53	No	Medium	53.0 ft²	Vaulted Roof

## Roof Insulation Library List

Name	Has Radiant Barrier	Effective R-value
ATT 16oc x6 Fblown 16" G1	No	44.669
EXT 16oc x10 Fbib R38 (R4.1/in) G1	No	31.682

## Whole House Infiltration

Infiltration	Measurement Type	Shelter Class
920.5 CFM at 50 Pa	Blower-door tested	4

# Building Summary



<b>Property</b> 1600 SW 27th St Lees Summit, MO 64082 Model: DD-7143 Community: Whispering Woods  1600 SW 27th St DDB WO Finished	<b>Organization</b> Endeavor Home Performance LLC Bryton Stoll 913-303-9282  <b>Builder</b> D and D Building, Inc	<b>Inspection Status</b> 2024-03-15 Rater ID (RTIN): 2596582 RESNET Registered (Confirmed)
--	---	---

## Mechanical Ventilation

Ventilation Type	Ventilation Rate [ft³ / Minute]	Operational hours per day	Fan Watts	Runs once every three hours	Energy Recovery Percent	Model Number	Manufacturer
Supply Only	71.3 CFM	24	24.96 Watts (Default)	Yes	0	DR120A3000	Honeywell

## Lighting

% Interior Fluorescent Lighting	% Interior LED Lighting	% Exterior Fluorescent Lighting	% Exterior LED Lighting	% Garage Fluorescent Lighting	% Garage LED Lighting
0	100	0	100	0	100

## Onsite Generation

None Present

## Onsite Generation Library List

None Present

## Solar Generation

None Present

## Dehumidifier

Name	Library Type
Dehumidifier	DR120A3000

# Building Summary



<b>Property</b> 1600 SW 27th St Lees Summit, MO 64082 Model: DD-7143 Community: Whispering Woods  1600 SW 27th St DDB WO Finished	<b>Organization</b> Endeavor Home Performance LLC Bryton Stoll 913-303-9282  <b>Builder</b> D and D Building, Inc	<b>Inspection Status</b> 2024-03-15 Rater ID (RTIN): 2596582 RESNET Registered (Confirmed)
--	---	---

## Dehumidifier Library List

Name	Equipment Type	Capacity [pints/day]	Integrated Energy Factor [liters/kWh]
DR120A3000	Whole Home	98.36	2.09

## Whole House Fan

None Present

## Whole House Fan Library List

None Present

## Conditioning Equipment

Name	Library Type	Serial Number	Heating Percent Load	Cooling Percent Load	Hot Water Percent Load	Location
Air Conditioner	ML18XC2-036-230 + CX35-36B + EL296UH070XE36B		0%	100%	0%	Conditioned Space
Furnace	EL296UH070XE36B		100%	0%	0%	Conditioned Space
Water Heater 1	EN6-50-DORT-1**		0%	0%	50%	Conditioned Space
Water Heater 2	EN6-50-DORT-1**		0%	0%	50%	Conditioned Space

## Equipment Type: EL296UH070XE36B

Equipment Type	Furnace
Fuel Type	Natural Gas
Distribution Type	Forced Air
Motor Type	ECM (Variable Speed)
Heating Efficiency	96 AFUE
Heating Capacity [kBtu/h]	64
Use default EAE	No
EAE [kWh]	327

# Building Summary

**Property**

1600 SW 27th St  
Lees Summit, MO 64082  
Model: DD-7143  
Community: Whispering Woods

1600 SW 27th St DDB  
WO Finished

**Organization**

Endeavor Home Performance LLC  
Bryton Stoll  
913-303-9282

**Builder**

D and D Building, Inc

**Inspection Status**

2024-03-15  
Rater ID (RTIN): 2596582  
RESNET Registered (Confirmed)



**Equipment Type: EN6-50-DORT-1\*\***

Equipment Type	Residential Water Heater
Fuel Type	Electric
Distribution Type	Hydronic Delivery (Radiant)
Hot Water Efficiency	0.92 UEF
Tank Capacity (gal.)	46
Hot Water Capacity [kBtu/h]	15.4
Recovery Efficiency	0.98

**Equipment Type: ML18XC2-036-230 + CX35-36B + EL296UH070XE36B**

Equipment Type	Air Conditioner
Fuel Type	Electric
Distribution Type	Forced Air
Motor Type	ECM (Variable Speed)
Heat Pump System Type	Split System
Cooling Efficiency	16.4 SEER2
Cooling Capacity [kBtu/h]	35

# Building Summary



**Property**

1600 SW 27th St  
Lees Summit, MO 64082  
Model: DD-7143  
Community: Whispering Woods

1600 SW 27th St DDB  
WO Finished

**Organization**

Endeavor Home Performance LLC  
Bryton Stoll  
913-303-9282

**Builder**

D and D Building, Inc

**Inspection Status**

2024-03-15  
Rater ID (RTIN): 2596582  
RESNET Registered (Confirmed)

## Distribution System

Distribution Type	Forced Air
Heating Equipment	Furnace
Cooling Equipment	Air Conditioner
Sq. Feet Served	3,311
# Return Grilles	1
Supply Duct R Value	0
Return Duct R Value	0
Supply Duct Area [ft²]	893.97
Return Duct Area [ft²]	165.55
Leakage to Outdoors	13 CFM @ 25Pa (0.39 / 100 ft²)
Total Leakage	247 CFM25
Total Leakage Duct Test Conditions	Post-Construction
Use Default Flow Rate	Yes
Duct 1	
Duct Location	Conditioned Space
Percent Supply Area	100
Percent Return Area	100
Duct 2	
Duct Location	Conditioned Space
Percent Supply Area	0
Percent Return Area	0
Duct 3	
Duct Location	Conditioned Space
Percent Supply Area	0
Percent Return Area	0
Duct 4	
Duct Location	Conditioned Space
Percent Supply Area	0
Percent Return Area	0
Duct 5	
Duct Location	Conditioned Space
Percent Supply Area	0
Percent Return Area	0
Duct 6	
Duct Location	Conditioned Space
Percent Supply Area	0
Percent Return Area	0

## HVAC Grading

HVAC Grading Not Conducted

## Ceiling Fan

Has Ceiling Fan	Yes
Cfm Per Watt	70

# Building Summary



**Property**

1600 SW 27th St  
Lees Summit, MO 64082  
Model: DD-7143  
Community: Whispering Woods

1600 SW 27th St DDB  
WO Finished

**Organization**

Endeavor Home Performance LLC  
Bryton Stoll  
913-303-9282

**Builder**

D and D Building, Inc

**Inspection Status**

2024-03-15  
Rater ID (RTIN): 2596582  
RESNET Registered (Confirmed)

## Water Distribution

Water Fixture Type	Standard
Use Default Hot Water Pipe Length	No
Hot Water Pipe Length [ft]	55
At Least R3 Pipe Insulation?	No
Hot Water Recirculation System?	No
Drain Water Heat Recovery?	No

## Clothes Dryer

Cef	3.01
Fuel Type	Electric
Field Utilization	Timer Controls
Is Outside Conditioned Space	No
Clothes Dryer Available	Yes
Defaults Type	HERS Reference

## Clothes Washer

Label Energy Rating	400 kWh/Year
Annual Gas Cost	\$27.00
Electric Rate	\$0.12/kWh
Gas Rate	\$1.09/Therm
Capacity	3
Imef	1
Defaults Type	HERS Reference
Load Type	Front-load
Loads Per Week	6
Is Outside Conditioned Space	No
Clothes Washer Available	Yes

## Dishwasher

Dishwasher Defaults Type	Custom
Dishwasher Size	Standard
Dishwasher Efficiency	240 kWh
Annual Gas Cost	\$24.00
Electric Rate	\$0.14/kWh
Gas Rate	\$1.21/Therm
Is Outside Conditioned Space	No
Dishwasher Available	Yes



# Building Summary

**Property**

1600 SW 27th St  
Lees Summit, MO 64082  
Model: DD-7143  
Community: Whispering Woods

1600 SW 27th St DDB  
WO Finished

**Organization**

Endeavor Home Performance LLC  
Bryton Stoll  
913-303-9282

**Builder**

D and D Building, Inc

**Inspection Status**

2024-03-15  
Rater ID (RTIN): 2596582  
RESNET Registered (Confirmed)



## Appliances and Controls

Programmable thermostat?	Yes
Range/Oven Fuel	Natural Gas
Convection Oven?	Yes
Induction Range?	No
Range/Oven Outside Conditioned Space?	No
Refrigerator Consumption	1,410 kWh/Year
Refrigerator Outside Conditioned Space?	No

## Notes