

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                         | Inspector:    | Outcome: | Date:                     |
|-------------------------------------|---------------|----------|---------------------------|
| <b>Water Line - Coliform Test 2</b> | Bobby Richest | Partial  | Wednesday, March 20, 2024 |

Informational:  
1 Misc 3-20-24 BR 2nd coliform sample was taking on 8" water main.

**Comments:**