

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233917
Address: 2230 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Partial	Thursday, March 21, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	Erosion control in compliance at time of inspection -Maintain EC methods until sod is in place
---	---------------------------------------	---

Comments: