

MARMIC FIRE & SAFETY

**1014 South Wall Avenue
Joplin, MO 64801
417-623-3584 (office) 417-626-3784 (fax)**

WHATABURGER #1276

**204 SW MO-150 Hwy
Lee's Summit, MO 64082**

Technical Information Submittal

Fire Suppression System

Tuesday, March 12, 2024

Whataburger –Lee’s Summit, MO
Fire Suppression System Submittal
Table of Contents

Sections

A) Product Information – Fire Suppression System

- a. 3 Gallon System Description (Single Tank System)
- b. 6 Gallon System Description (Double Tank System)
- c. AnsulEX Extinguishing Agent (79372)
- d. Regulated Release Assembly- Mechanical (429853)
- e. Single Tank Enclosure Assembly (429862)
- f. Agent Tank Assembly - 3 Gallon Stainless Steel (429862)
- g. Gas Cartridges: LT-30-R & Double Tank (423435 & 423493)
- h. Nozzles:
 - 1N Nozzle – 1 Flow Point (419335)
 - 1W Nozzle – 1 Flow Point (419336)
 - 290 Nozzle – 2 Flow Points (419342)
 - 2W Nozzle – 2 Flow Points (439840)
- i. Metal Blow-off Caps (434707)
- j. “Quik-Seal” Adapter (77285)
- k. “Compression Seal” Adapter (79151)
- l. “Hood Seal” Adapter (423253)
- m. Detectors: The Series Detector (435547)
- n. Pulley Elbow (423250)
- o. Ansul Stainless Steel Cable (79653)
- p. Remote Manual Pull Station (434618)
- q. Electrical Switch (423881)
- r. Alarm Initiating Switch (428311)
- s. Fusible Link – 360 Degree (439244)
- t. In-Line Burst Disc Assembly (416970)

B) Design Data

- a. Drawings

C) Supporting Documents

- a. UL Listing
- b. System Design

D) Installer Qualifications

- a. Company Fire Alarm License
- b. Sales / Technicians Fire Alarm Licenses

SECTION B

DESIGN DATA

Section B




Whataburger

Fire Suppression System Submittal

↓ = NOZZLE


X = AIM POINT

D = DETECTOR 360°F



NOZZLE HEIGHT
16"
"LOW PROXIMITY"

ELECTRIC
FRYERS
10" DRIP



INSTALLATION BY:
Marmic Fire & Safety
1014 S Wall Ave,
Joplin, MO 64801
(417) 623-3684

HOOD SIZE - 74"
PLENUM - 74" x 13"
DUCT - 15" x 10"

NFPA 96(2017 EDITION)
NFPA17A (2017 EDITION)

Marmic Fire & Safety
1014 S Wall Ave
Joplin, MO 64801
(417) 623-3684

WHATABURGER
UNIT 1276
204 SW MO-150 HWY
LEES SUMMIT, MO 64082

DRAWN BY: C.L.C.
CHECKED BY: C.A.L.
DATE: 3/12/2024
SCALE: N.T.S.

REVISION NO. & DATE

TITLE:
FIRE
SUPPRESSION
SYSTEM

SHEET NO:

FS2

DWG NO.

2 OF 2