

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20224993

Address: 520 NE TOWN CENTRE DR, Unit:P, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, March 21, 2024

**Corrective Action Required:**

1	Misc	Two NW and NE LP piers: -Support rebar 3" off from soil -Drive grounding rod into soil and install #6 ft grounding conductor
---	------	--

**Comments:**