

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240759
Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Bobby Richest	Passed	Thursday, March 21, 2024

Informational:
1 Misc 3-19-24 BR Driveway is formed up and compacted ready for concrete.
3-21-24 BR Driveway is constructed to LS specifications.

Comments: