

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232899
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|---------------|----------|------------------------|
| Water Line - Coliform Test 1 | Bobby Richest | Passed | Friday, March 22, 2024 |

Informational:
1 Misc 3-19-24 BR 1st coliform sample was taking on 12" water main.
3-22-24 BR 1st coliform sample pass.

Comments: